



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PO Box 47775 • Olympia, Washington 98504-7775 • (360) 407-6300

May 5, 2016

Queen Ann Waterworks
Attn: Gerard and Catherine Fitzpatrick
91 NE Queen Ann Drive
Belfair, WA 98528

Re: Water Right No. G2-28466 for Queen Ann Waterworks

Dear Mr. and Mrs. Fitzpatrick:

In response to your request, you are hereby granted an extension to put the water to full beneficial use for the reasons below:

- Due diligence is shown in development of water under this permit. Queen Ann Waterworks is currently serving 14 residential connections and seeking Group A status.
- The water system planning process has been initiated. Additional time is needed for plan submittal and approval in order apply water to full beneficial use.

The new deadline to submit your *Proof of Appropriation of Water* is **June 1, 2018**.

To keep this permit in good standing, you must:

1. Make reasonable and timely efforts to submit a draft Water System Plan to the Department of Health. At the water system planning pre-plan meeting, Todd Krause identified a target date of September 1, 2016, for the initial submittal.
2. Exercise due diligence by promptly addressing all comments you receive in response to water system plan submittal.
3. Submit monthly and annual source meter records to our office by the end of February, each year.
4. Operate the water system in compliance with all water right permit limitations and provisions.
5. Attach and maintain a Unique Well ID tag to the well. We will be mailing you a tag in the near future.
6. Submit a copy of the amended Queen Ann Waterworks water service contract/agreement showing that only in-house use of water is allowed. We originally requested this submittal in our letter dated February 10, 2015.
7. Promptly investigate and take affirmative steps toward reducing unaccounted-for water. The source meter data you submitted indicates that 38% of total withdrawals in 2015 was not accounted for.

If you have any questions, please contact Marie Peter at (360) 407-0279 or



marie.peter@ecy.wa.gov .

YOUR RIGHT TO APPEAL

You have a right to appeal this decision to the Pollution Control Hearing Board (PCHB) within 30 days of the date of receipt of this decision. The appeal process is governed by Chapter 43.21B RCW and Chapter 371-08 WAC. "Date of receipt" is defined in RCW 43.21B.001(2).

To appeal you must do the following within 30 days of the date of receipt of this decision:

- File your appeal and a copy of this decision with the PCHB (see addresses below). Filing means actual receipt by the PCHB during regular business hours.
- Serve a copy of your appeal and this decision on Ecology in paper form - by mail or in person. (See addresses below.) E-mail is not accepted.

You must also comply with other applicable requirements in Chapter 43.21B RCW and Chapter 371-08 WAC.

ADDRESS AND LOCATION INFORMATION


Street Addresses	Mailing Addresses
Department of Ecology Attn: Appeals Processing Desk 300 Desmond Drive SE Lacey, WA 98503	Department of Ecology Attn: Appeals Processing Desk PO Box 47608 Olympia, WA 98504-7608
Pollution Control Hearings Board 1111 Israel RD SW STE 301 Tumwater, WA 98501	Pollution Control Hearings Board PO Box 40903 Olympia, WA 98504-0903

For additional information visit the Environmental Hearings Office Website: <http://www.eho.wa.gov> .

To find laws and agency rules visit the Washington State Legislature Website:

<http://www1.leg.wa.gov/CodeReviser>.

Sincerely,



Michael J. Gallagher
Section Manager
SWRO Water Resources

cc: Todd Krause, Northwest Water Systems
Susan Clark, DOH Southwest Drinking Water

Enclosures: *Proof of Appropriation of Water*
Your Right to Be Heard

BY CERTIFIED MAIL: 7015 0640 0007 2151 7132